

Goniophotometry Report

1_PHOT_NINETY-NINE-1875lmChip-3500K-58Deg_2303
www.factorylux.com



Tested Light Source - 1_PHOT_NINETY-NINE-1875lmChip-3500K-58Deg_2303

Laboratory and Equipment

Laboratory Owner and Location
Goniospectrometer System and Type
Spectrometer Manufacturer and Model

Factorylux, Greenhill Mills, Hebden Bridge, HX7 5QF, UK
BaseSpion – Type C, horizontal
Ibsen Photonics, Denmark – Freedom VIS (Custom Viso)

Measurement Conditions

Number of C-planes and Resolution
 γ (gamma)-Resolution
Test Distance
Input Power, Power and Displ. Factors
Input RMS Voltage and Current
Frequency of Input Power


32 planes – 11.25°
2.5°
1.50 m
14.6 W – PF 0.46 – DPF 0.79
242 V – 0.130 A
50.1 Hz

Main Light Measurement Results

Output
Efficiency
Peak Intensity and Beam Angle
Color Rendering Index

1408 lm
96 lm/W
1613 cd – 59°
CRI 93.0

Light Intensity Distribution




Goniophotometry Report

1_PHOT_NINETY-NINE-1875lmChip-3500K-58Deg_2303
www.factorylux.com



Luminous Intensity diagram

Unit: 0-100% of peak intensity



Main Values

Output (total Lumen)	1408 lm
Peak Intensity	1613 cd
Beam Angle (50%)	59°
Beam Angle (90%)	59°
Beam Angle (10%)	59°

Cut-off Angle

Average 2,5%	90.8°
--------------	-------

Field Angle

Average 10%	79.4°
-------------	-------


Intensity Ratio

In 120° cone	98.3%
In 90° cone	96.2%

C000-C180

C090-C270

Linear distribution diagram - Intensity (candela) vs γ-angle




Goniophotometry Report

1_PHOT_NINETY-NINE-1875lmChip-3500K-58Deg_2303
www.factorylux.com




Iso-intensity Diagram (Iso-candela)



90 %	1451.6 cd
80 %	1290.3 cd
70 %	1129.0 cd
60 %	967.7 cd
50 %	806.4 cd
40 %	645.2 cd
30 %	483.9 cd
20 %	322.6 cd
10 %	161.3 cd

Peak intensity: 1612.9 cd
Number of c-planes: 32

Iso-illuminance Diagram (Iso-lux)



50.0 %	8.1 lx
30.0 %	4.8 lx
10.0 %	1.6 lx
5.0 %	0.8 lx
3.0 %	0.5 lx


Peak illuminance: 16.1 lx
Mounting height: 10.0 m
Number of c-planes: 32

Goniophotometry Report

1_PHOT_NINETY-NINE-1875lmChip-3500K-58Deg_2303
www.factorylux.com



Beam Details



Beam intensities from 1 – 20 m

1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	m
3.3	6.6	9.8	13.1	16.4	19.7	23	26.2	29.5	32.8	36.1	39.4	42.7	45.9	49.2	52.5	55.8	59.1	62.3	65.6	ft
1613	403	179	101	65	45	33	25	20	16	13	11	10	8	7	6	6	5	4	4	lux
149.8	37.5	16.6	9.4	6	4.2	3.1	2.3	1.8	1.5	1.2	1	0.9	0.8	0.7	0.6	0.5	0.5	0.4	0.4	fc

Intensities in 0° c-plane

0°	2°	4°	6°	8°	10°	12°	14°	16°	18°	20°	22°	24°	26°	28°	30°	32°	34°	36°	38°	γ
1613	1611	1602	1589	1571	1549	1522	1488	1450	1406	1352	1284	1193	1068	923	768	614	469	341	235	cd
100%	100%	99%	99%	97%	96%	94%	92%	90%	87%	84%	80%	74%	66%	57%	48%	38%	29%	21%	15%	of 0°val

Intensities in 90° c-plane

0°	2°	4°	6°	8°	10°	12°	14°	16°	18°	20°	22°	24°	26°	28°	30°	32°	34°	36°	38°	γ
1613	1611	1602	1589	1571	1549	1522	1488	1450	1406	1352	1284	1193	1068	923	768	614	469	341	235	cd
100%	100%	99%	99%	97%	96%	94%	92%	90%	87%	84%	80%	74%	66%	57%	48%	38%	29%	21%	15%	of 0°val

Intensities in 180° c-plane

0°	2°	4°	6°	8°	10°	12°	14°	16°	18°	20°	22°	24°	26°	28°	30°	32°	34°	36°	38°	γ
1613	1611	1602	1589	1571	1549	1522	1488	1450	1406	1352	1284	1193	1068	923	768	614	469	341	235	cd
100%	100%	99%	99%	97%	96%	94%	92%	90%	87%	84%	80%	74%	66%	57%	48%	38%	29%	21%	15%	of 0°val

Intensities in 270° c-plane

0°	2°	4°	6°	8°	10°	12°	14°	16°	18°	20°	22°	24°	26°	28°	30°	32°	34°	36°	38°	γ
1613	1611	1602	1589	1571	1549	1522	1488	1450	1406	1352	1284	1193	1068	923	768	614	469	341	235	cd
100%	100%	99%	99%	97%	96%	94%	92%	90%	87%	84%	80%	74%	66%	57%	48%	38%	29%	21%	15%	of 0°val

Goniophotometry Report

1_PHOT_NINETY-NINE-1875lmChip-3500K-58Deg_2303
www.factorylux.com



Light Planning – UGR table

Uncorrected, comprehensive UGR table according to 117-1995

Reflectances											
	p Ceiling	70	70	50	50	30	70	70	50	50	30
	p Walls	50	30	50	30	30	50	30	50	30	30
	p Floor	20	20	20	20	20	20	20	20	20	20
Room size											
H = mounting height above eye level											
X	Y	Viewed Crosswise (Viewing direction orthogonal to lamp length axis)					Viewed Endwise (Viewing direction parallel to lamp length axis)				
2H	2H	19.9	20.5	20.0	20.7	20.9	19.9	20.5	20.0	20.7	20.9
	3H	19.8	20.5	20.1	20.7	20.9	19.8	20.5	20.1	20.7	20.9
	4H	19.8	20.6	20.2	20.8	21.0	19.8	20.6	20.2	20.8	21.0
	6H	19.9	20.6	20.2	20.9	21.2	19.9	20.6	20.2	20.9	21.2
	8H	19.9	20.5	20.3	20.9	21.2	19.9	20.5	20.3	20.9	21.2
	12H	19.9	20.5	20.3	20.8	21.3	19.9	20.5	20.3	20.8	21.3
4H	2H	19.6	20.3	20.0	20.6	20.8	19.6	20.3	20.0	20.6	20.8
	3H	19.8	20.3	20.1	20.7	21.1	19.8	20.3	20.1	20.7	21.1
	4H	19.8	20.4	20.2	20.8	21.3	19.8	20.4	20.2	20.8	21.3
	6H	19.9	20.5	20.4	20.8	21.2	19.9	20.5	20.4	20.8	21.2
	8H	20.0	20.5	20.5	20.8	21.2	20.0	20.5	20.5	20.8	21.2
	12H	20.0	20.4	20.5	20.8	21.2	20.0	20.4	20.5	20.8	21.2
8H	4H	19.8	20.3	20.3	20.7	21.0	19.8	20.3	20.3	20.7	21.0
	6H	20.0	20.4	20.5	20.8	21.4	20.0	20.4	20.5	20.8	21.4
	8H	20.1	20.4	20.6	20.9	21.5	20.1	20.4	20.6	20.9	21.5
	12H	20.1	20.4	20.7	20.9	21.5	20.1	20.4	20.7	20.9	21.5
12H	4H	19.8	20.2	20.3	20.6	21.0	19.8	20.2	20.3	20.6	21.0
	6H	20.1	20.3	20.6	20.8	21.5	20.1	20.3	20.6	20.8	21.5
	8H	20.1	20.3	20.7	20.9	21.5	20.1	20.3	20.7	20.9	21.5


Variations with the observer position for the luminaire spacings, S:

S = 1.0H	4.6 / -3.6	4.6 / -3.6
S = 1.5H	7.2 / -3.8	7.2 / -3.8
S = 2.0H	9.1 / -4.1	9.1 / -4.1

Coefficients of Utilization

Ceiling reflectance	80			70			50			30			10			0		
Wall reflectance	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0
Floor reflectance	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	0
RCR		(RCR: Room Cavity Ratio)			Room Values are expressed as percentage of Lumen delivered to the task surface													
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100
1	113	111	108	106	111	109	106	104	104	103	101	101	99	98	97	96	95	93
2	108	103	99	96	106	101	98	95	98	95	92	95	93	91	92	90	89	87
3	103	96	91	87	101	95	90	87	92	88	85	90	87	84	88	85	83	81
4	98	90	85	80	96	89	84	80	87	82	79	85	81	78	83	80	77	76
5	93	85	79	75	91	84	78	74	82	77	74	80	76	73	79	75	72	71
6	88	80	74	69	87	79	73	69	77	72	69	76	72	68	75	71	68	66
7	84	75	69	65	83	74	69	65	73	68	64	72	67	64	71	67	64	62
8	80	71	65	61	79	70	65	61	69	64	61	68	64	60	67	63	60	59
9	76	67	61	57	75	66	61	57	66	61	57	65	60	57	64	60	57	55
10	73	63	58	54	72	63	58	54	62	57	54	61	57	54	61	57	53	52

1_PHOT_NINETY-NINE-1875lmChip-3500K-58Deg_2303
www.factorylux.com



Zonal Lumen Summary

[illegible]

Goniophotometry Report

1_PHOT_NINETY-NINE-1875lmChip-3500K-58Deg_2303
www.factorylux.com



Outdoor Light Planning

Lumen per Zone

Zone (γ)	Lumen	% Total
0-10°	151 lm	10.7%
10-20°	412 lm	29.3%
20-30°	506 lm	35.9%
30-40°	256 lm	18.2%
40-50°	42 lm	3.0%
50-60°	17 lm	1.2%
60-70°	13 lm	0.9%
70-80°	8 lm	0.6%
80-90°	2 lm	0.2%
90-100°	0 lm	0.0%
100-110°	0 lm	0.0%
110-120°	0 lm	0.0%
120-130°	0 lm	0.0%
130-140°	0 lm	0.0%
140-150°	0 lm	0.0%
150-160°	0 lm	0.0%
160-170°	0 lm	0.0%
170-180°	0 lm	0.0%
Total	1408 lm	100.0%

Zonal Lumen summary

Zone (γ)	Lumen	% Total
0-30°	1069 lm	75.9%
0-40°	1325 lm	94.1%
0-60°	1384 lm	98.3%
60-90°	24 lm	1.7%
70-100°	11 lm	0.8%
90-120°	0 lm	0.0%
0-90°	1408 lm	100.0%
90-180°	0 lm	0.0%
0-180°	1408 lm	100.0%

BUG rating


	Lumen	% Total
Forward light		
Low(0-30°)	533 lm	37.9%
Medium(30-60°)	159 lm	11.3%
High(60-80°)	11 lm	0.8%
Very high(80-90°)	1 lm	0.1%
Back light		
Low(0-30°)	533 lm	37.9%
Medium(30-60°)	159 lm	11.3%
High(60-80°)	11 lm	0.8%
Very high(80-90°)	1 lm	0.1%
Uplight		
Low(90-100°)	0 lm	0.0%
High(100-180°)	0 lm	0.0%

Intensity peaks

Max intensity	1613 cd
Intensity, 90°	0 cd
Intensity, 0°	1613 cd

IESNA TM-15-07 Luminaire Classification System For Outdoor Luminaires

BUG rating B2 U1 G0



Goniophotometry Report

1_PHOT_NINETY-NINE-1875lmChip-3500K-58Deg_2303
www.factorylux.com



Power Details


Input Power

Power feed to light source	14.6 W
Frequency of input power	50.1 Hz
RMS Input voltage feed, V_{RMS}	242 V
RMS Input current feed, I_{RMS}	0.130 A
Volt-Ampere or apparent power = $V_{RMS} * I_{RMS}$	31.59 VA
Displacement factor of AC power feed	0.79
Power factor of AC current feed	0.46
Total harmonic distortion of the current	136.22%
Total harmonic distortion of the voltage	1.27%

Efficiency

Radiated power efficiency	35.3%
<div><div></div></div>	
Lumen efficiency	96 lm/W
<div><div></div></div>	

Input Power Curve



Goniophotometry Report


1_PHOT_NINETY-NINE-1875lmChip-3500K-58Deg_2303
www.factorylux.com



Color Measurements

Correlated Color Temperature CCT = 3500 K
Color Rendering TM30-18 R_f 90.2 — R_g 98.1
Color Shift, CIE duv Duv ±0.0003

Spectral distribution



Color details

Correlated Color Temperature	CCT = 3500 K	Color coordinates CIE 1931	(x;y) = (0.406;0.391)
Color Rendering Index	CRI 94.0	Color coordinate CIEs 1960	(u;v) = (0.236;0.341)
Color Rendering Index, R9 (red component)	R9 = 77.7	Color deviation from BBL	Duv = ±0.0003
Color Rendering TM30-18	R _f 90.2 — R _g 98.1	Color coordinate CIEs 1976 (CIELUV)	(u';v') = (0.236;0.236)
Color Quality Scale	CQS = 92.3		

Goniophotometry Report

1_PHOT_NINETY-NINE-1875lmChip-3500K-58Deg_2303
www.factorylux.com



CIE 1931



CIE 1931 – zoomed on Planckian locus




Color Rendering Index per reference color (CIE 1995)



CRI R values, only R1-R8 are used to calculate final CRI value

R1	R2	R3	R4	R5	R6	R7	R8	R9	R10	R11	R12	R13	R14	R15
97.3	97.2	95.9	93.4	95.9	93.5	90.9	87.9	77.7	96.6	94.1	77.1	98.8	99.0	96.4


TM30-18 Rf-values per hue bin




TM30 C values, 16 binned values out of total of 99 C values

C1	C2	C3	C4	C5	C6	C7	C8	C9	C10	C11	C12	C13	C14	C15	C16
90.6	93.4	93.6	92.7	91.6	95.0	90.7	91.6	88.0	84.8	86.5	89.9	91.7	88.5	88.1	87.0

Spectral power distribution (SPD) / W/nm – 0-100%



Color Quality Scale by reference color



CQS Q values

Q1	Q2	Q3	Q4	Q5	Q6	Q7	Q8	Q9	Q10	Q11	Q12	Q13	Q14	Q15
90.6	97.2	89.6	86.2	89.1	92.3	95.5	94.7	99.4	97.0	94.0	92.8	92.6	92.1	91.8