

Goniophotometry Report

1_PHOT_NINETY-NINE-2125lmChip-3000K-38Deg_2303
www.factorylux.com



Tested Light Source - 1_PHOT_NINETY-NINE-2125lmChip-3000K-38Deg_2303

Laboratory and Equipment

Laboratory Owner and Location
Goniospectrometer System and Type
Spectrometer Manufacturer and Model

Factorylux, Greenhill Mills, Hebden Bridge, HX7 5QF, UK
BaseSpion – Type C, horizontal
Ibsen Photonics, Denmark – Freedom VIS (Custom Viso)

Measurement Conditions

Number of C-planes and Resolution
 γ (gamma)-Resolution
Test Distance
Input Power, Power and Displ. Factors
Input RMS Voltage and Current
Frequency of Input Power


32 planes – 11.25°
1.5°
1.50 m
15.9 W – PF 0.98 – DPF 0.98
239 V – 0.068 A
50 Hz

Main Light Measurement Results

Output
Efficiency
Peak Intensity and Beam Angle
Color Rendering Index

1549 lm
97 lm/W
3042 cd – 38.2°
CRI 92.7

Light Intensity Distribution




Goniophotometry Report

1_PHOT_NINETY-NINE-2125lmChip-3000K-38Deg_2303
www.factorylux.com



Luminous Intensity diagram

Unit: 0-100% of peak intensity



Main Values

Output (total Lumen)	1549 lm
Peak Intensity	3042 cd
Beam Angle (50%)	38.2°
Beam Angle (90%)	38.2°
Beam Angle (10%)	38.2°

Cut-off Angle

Average 2,5%	94°
--------------	-----

Field Angle

Average 10%	67.6°
-------------	-------


Intensity Ratio

In 120° cone	97.5%
In 90° cone	92.9%

C000-C180

C090-C270

Linear distribution diagram - Intensity (candela) vs γ-angle




Goniophotometry Report

1_PHOT_NINETY-NINE-2125lmChip-3000K-38Deg_2303
www.factorylux.com




Iso-intensity Diagram (Iso-candela)



90 %	2737.4 cd
80 %	2433.3 cd
70 %	2129.1 cd
60 %	1825.0 cd
50 %	1520.8 cd
40 %	1216.6 cd
30 %	912.5 cd
20 %	608.3 cd
10 %	304.2 cd

Peak intensity: 3041.6 cd
Number of c-planes: 32

Iso-illuminance Diagram (Iso-lux)



50.0 %	15.2 lx
30.0 %	9.1 lx
10.0 %	3.0 lx
5.0 %	1.5 lx
3.0 %	0.9 lx


Peak illuminance: 30.4 lx
Mounting height: 10.0 m
Number of c-planes: 32

Goniophotometry Report

1_PHOT_NINETY-NINE-2125lmChip-3000K-38Deg_2303
www.factorylux.com



Beam Details



Beam intensities from 1 – 20 m

1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	m
3.3	6.6	9.8	13.1	16.4	19.7	23	26.2	29.5	32.8	36.1	39.4	42.7	45.9	49.2	52.5	55.8	59.1	62.3	65.6	ft
3042	760	338	190	122	84	62	48	38	30	25	21	18	16	14	12	11	9	8	8	lux
282.6	70.6	31.4	17.7	11.3	7.8	5.8	4.4	3.5	2.8	2.3	2	1.7	1.4	1.3	1.1	1	0.9	0.8	0.7	fc

Intensities in 0° c-plane

0°	2°	4°	6°	8°	10°	12°	14°	16°	18°	20°	22°	24°	26°	28°	30°	32°	34°	36°	38°	γ
3042	3032	2986	2892	2751	2567	2356	2128	1888	1648	1414	1191	981	793	629	491	382	297	231	183	cd
100%	100%	98%	95%	90%	84%	77%	70%	62%	54%	46%	39%	32%	26%	21%	16%	13%	10%	8%	6%	of 0°val

Intensities in 90° c-plane

0°	2°	4°	6°	8°	10°	12°	14°	16°	18°	20°	22°	24°	26°	28°	30°	32°	34°	36°	38°	γ
3042	3032	2986	2892	2751	2567	2356	2128	1888	1648	1414	1191	981	793	629	491	382	297	231	183	cd
100%	100%	98%	95%	90%	84%	77%	70%	62%	54%	46%	39%	32%	26%	21%	16%	13%	10%	8%	6%	of 0°val

Intensities in 180° c-plane

0°	2°	4°	6°	8°	10°	12°	14°	16°	18°	20°	22°	24°	26°	28°	30°	32°	34°	36°	38°	γ
3042	3032	2986	2892	2751	2567	2356	2128	1888	1648	1414	1191	981	793	629	491	382	297	231	183	cd
100%	100%	98%	95%	90%	84%	77%	70%	62%	54%	46%	39%	32%	26%	21%	16%	13%	10%	8%	6%	of 0°val

Intensities in 270° c-plane

0°	2°	4°	6°	8°	10°	12°	14°	16°	18°	20°	22°	24°	26°	28°	30°	32°	34°	36°	38°	γ
3042	3032	2986	2892	2751	2567	2356	2128	1888	1648	1414	1191	981	793	629	491	382	297	231	183	cd
100%	100%	98%	95%	90%	84%	77%	70%	62%	54%	46%	39%	32%	26%	21%	16%	13%	10%	8%	6%	of 0°val

Goniophotometry Report

1_PHOT_NINETY-NINE-2125lmChip-3000K-38Deg_2303

www.factorylux.com



Light Planning – UGR table



Uncorrected, comprehensive UGR table according to 117-1995

Reflectances											
	ρ Ceiling	70	70	50	50	30	70	70	50	50	30
	ρ Walls	50	30	50	30	30	50	30	50	30	30
	ρ Floor	20	20	20	20	20	20	20	20	20	20
Room size											
H = mounting height above eye level											
X	Y	Viewed Crosswise (Viewing direction orthogonal to lamp length axis)					Viewed Endwise (Viewing direction parallel to lamp length axis)				
2H	2H	19.2	19.8	19.3	20.0	20.2	19.2	19.8	19.3	20.0	20.2
	3H	19.5	20.2	19.9	20.4	20.6	19.5	20.2	19.9	20.4	20.6
	4H	19.6	20.3	20.0	20.6	20.8	19.6	20.3	20.0	20.6	20.8
	6H	19.8	20.4	20.1	20.7	21.0	19.8	20.4	20.1	20.7	21.0
	8H	19.8	20.4	20.2	20.7	21.1	19.8	20.4	20.2	20.7	21.1
	12H	19.8	20.4	20.2	20.7	21.2	19.8	20.4	20.2	20.7	21.2
4H	2H	19.2	19.9	19.6	20.1	20.4	19.2	19.9	19.6	20.1	20.4
	3H	19.8	20.4	20.2	20.7	21.2	19.8	20.4	20.2	20.7	21.2
	4H	20.0	20.5	20.4	20.9	21.5	20.0	20.5	20.4	20.9	21.5
	6H	20.2	20.7	20.7	21.1	21.4	20.2	20.7	20.7	21.1	21.4
	8H	20.2	20.7	20.7	21.1	21.4	20.2	20.7	20.7	21.1	21.4
	12H	20.3	20.6	20.8	21.0	21.5	20.3	20.6	20.8	21.0	21.5
8H	4H	20.0	20.5	20.6	20.9	21.2	20.0	20.5	20.6	20.9	21.2
	6H	20.3	20.7	20.8	21.1	21.6	20.3	20.7	20.8	21.1	21.6
	8H	20.5	20.7	21.0	21.2	21.9	20.5	20.7	21.0	21.2	21.9
	12H	20.5	20.7	21.1	21.3	21.9	20.5	20.7	21.1	21.3	21.9
12H	4H	20.0	20.4	20.5	20.8	21.3	20.0	20.4	20.5	20.8	21.3
	6H	20.4	20.6	20.9	21.1	21.8	20.4	20.6	20.9	21.1	21.8
	8H	20.5	20.7	21.1	21.2	21.8	20.5	20.7	21.1	21.2	21.8
Variations with the observer position for the luminaire spacings, S:											
S = 1.0H		2.0 / -1.2					2.0 / -1.2				
S = 1.5H		3.9 / -1.6					3.9 / -1.6				
S = 2.0H		5.5 / -2.2					5.5 / -2.2				

Coefficients of Utilization

Ceiling reflectance	80			70			50			30			10			0		
Wall reflectance	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0
Floor reflectance	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	0
RCR		(RCR: Room Cavity Ratio)			Room Values are expressed as percentage of Lumen delivered to the task surface													
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100
1	114	111	108	106	111	109	107	105	105	103	101	101	100	98	98	97	96	94
2	108	104	100	96	106	102	98	95	99	96	93	96	93	91	93	91	89	88
3	103	97	92	89	101	96	91	88	93	90	87	91	88	85	89	86	84	82
4	99	91	86	82	97	90	86	82	88	84	81	86	83	80	84	81	79	78
5	94	86	81	77	93	85	80	77	84	79	76	82	78	75	81	77	75	73
6	90	82	76	72	89	81	76	72	80	75	72	78	74	71	77	73	71	69
7	86	78	72	68	85	77	72	68	76	71	68	75	71	67	74	70	67	66
8	83	74	69	65	82	74	68	65	72	68	64	71	67	64	71	67	64	63
9	80	71	65	62	78	70	65	62	69	65	61	68	64	61	68	64	61	60
10	76	68	62	59	75	67	62	59	66	62	59	66	61	58	65	61	58	57

1_PHOT_NINETY-NINE-2125lmChip-3000K-38Deg_2303
www.factorylux.com



Goniophotometry Report

1_PHOT_NINETY-NINE-2125lmChip-3000K-38Deg_2303
www.factorylux.com



Outdoor Light Planning

Lumen per Zone

Zone (γ)	Lumen	% Total
0-10°	269 lm	17.4%
10-20°	549 lm	35.5%
20-30°	406 lm	26.2%
30-40°	172 lm	11.1%
40-50°	72 lm	4.7%
50-60°	40 lm	2.6%
60-70°	25 lm	1.6%
70-80°	11 lm	0.7%
80-90°	3 lm	0.2%
90-100°	0 lm	0.0%
100-110°	0 lm	0.0%
110-120°	0 lm	0.0%
120-130°	0 lm	0.0%
130-140°	0 lm	0.0%
140-150°	0 lm	0.0%
150-160°	0 lm	0.0%
160-170°	0 lm	0.0%
170-180°	0 lm	0.0%
Total	1549 lm	100.0%

Intensity peaks

Max intensity	3042 cd
Intensity, 90°	0 cd
Intensity, 0°	3042 cd

Zonal Lumen summary


Zone (γ)	Lumen	% Total
0-30°	1225 lm	79.1%
0-40°	1397 lm	90.2%
0-60°	1510 lm	97.5%
60-90°	39 lm	2.5%
70-100°	14 lm	0.9%
90-120°	0 lm	0.0%
0-90°	1549 lm	100.0%
90-180°	0 lm	0.0%
0-180°	1549 lm	100.0%

BUG rating

	Lumen	% Total
Forward light		
Low(0-30°)	612 lm	39.5%
Medium(30-60°)	143 lm	9.2%
High(60-80°)	18 lm	1.2%
Very high(80-90°)	2 lm	0.1%
Back light		
Low(0-30°)	612 lm	39.5%
Medium(30-60°)	143 lm	9.2%
High(60-80°)	18 lm	1.2%
Very high(80-90°)	2 lm	0.1%
Uplight		
Low(90-100°)	0 lm	0.0%
High(100-180°)	0 lm	0.0%

IESNA TM-15-07 Luminaire Classification System For Outdoor Luminaires

BUG rating B2 U1 G0



Goniophotometry Report

1_PHOT_NINETY-NINE-2125lmChip-3000K-38Deg_2303
www.factorylux.com



Power Details


Input Power

Power feed to light source	15.9 W
Frequency of input power	50 Hz
RMS Input voltage feed, V_{RMS}	239 V
RMS Input current feed, I_{RMS}	0.068 A
Volt-Ampere or apparent power = $V_{RMS} * I_{RMS}$	16.19 VA
Displacement factor of AC power feed	0.98
Power factor of AC current feed	0.98
Total harmonic distortion of the current	6.21%
Total harmonic distortion of the voltage	1.09%

Efficiency

Radiated power efficiency	35.7%
<div><div></div></div>	
Lumen efficiency	97 lm/W
<div><div></div></div>	

Input Power Curve



Goniophotometry Report


1_PHOT_NINETY-NINE-2125lmChip-3000K-38Deg_2303
www.factorylux.com



Color Measurements

Correlated Color Temperature	CCT = 3000 K
Color Rendering TM30-18	R _f 91.0 — R _g 97.7
Color Shift, CIE duv	Duv ±0.0003

Spectral distribution



Color details


Correlated Color Temperature	CCT = 3000 K	Color coordinates CIE 1931	(x;y) = (0.437;0.404)
Color Rendering Index	CRI 94.1	Color coordinate CIEs 1960	(u;v) = (0.251;0.348)
Color Rendering Index, R9 (red component)	R9 = 68.6	Color deviation from BBL	Duv = ±0.0003
Color Rendering TM30-18	R _f 91.0 — R _g 97.7	Color coordinate CIEs 1976 (CIELUV)	(u';v') = (0.251;0.251)
Color Quality Scale	CQS = 91.8		

Goniophotometry Report

1_PHOT_NINETY-NINE-2125ImChip-3000K-38Deg_2303
www.factorylux.com




CIE 1931



CIE 1931 – zoomed on Planckian locus




Color Rendering Index per reference color (CIE 1995)




CRI R values, only R1-R8 are used to calculate final CRI value

R1	R2	R3	R4	R5	R6	R7	R8	R9	R10	R11	R12	R13	R14	R15
95.7	99.5	97.3	93.1	95.2	96.2	91.3	84.6	68.6	98.2	94.1	81.6	97.2	99.5	92.5

Spectral power distribution (SPD) / W/nm – 0-100%




TM30-18 Rf-values per hue bin



TM30 C values, 16 binned values out of total of 99 C values

C1	C2	C3	C4	C5	C6	C7	C8	C9	C10	C11	C12	C13	C14	C15	C16
90.6	93.4	93.9	93.6	92.8	95.9	90.1	94.0	89.7	86.4	89.2	89.9	90.9	88.1	88.2	86.1

Color Quality Scale by reference color



CQS Q values

Q1	Q2	Q3	Q4	Q5	Q6	Q7	Q8	Q9	Q10	Q11	Q12	Q13	Q14	Q15
88.8	95.1	91.2	88.2	89.9	91.9	93.8	93.7	97.0	96.5	94.4	93.2	92.8	89.6	89.5